



# Ashford Water Treatment Plant

**Sampling Point: Ashford Water Treatment Plant**

**EPL No. 4412**

**Licence Period 6 September 2011 to 5 September 2012**

**Licensee: Inverell Shire Council**

<http://www.environment.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4412&id=4412&option=licence&searchrange=licence&range=POEO licence&prp=no&status=Issued>

**144 Otho Street, Inverell**

**Monitoring Frequency - Monthly**

		Quantity	Measurement	Limit	Units
Sampled	6/03/2012	Aluminium (Total)	0.049	0.1	mg/L
Obtained	26/03/2012	pH	6.5	6.5-8.5	
Published	1/06/2012	Suspended Solids	16	20	mg/L
Sampled	4/04/2012	Aluminium (Total)		0.1	mg/L
Obtained	17/04/2012	pH		6.5-8.5	
Published	1/06/2012	Suspended Solids		20	mg/L
Sampled	1/05/2012	Aluminium (Total)	0.084	0.1	mg/L
Obtained	9/05/2012	pH	6.6	6.5-8.5	
Published	1/06/2012	Suspended Solids	7	20	mg/L
Sampled	19/06/2012	Aluminium (Total)	0.068	0.1	mg/L
Obtained	27/06/2012	pH	6.6	6.5-8.5	
Published	3/07/2012	Suspended Solids	5	20	mg/L
Sampled	10/07/2012	Aluminium (Total)	0.095	0.1	mg/L
Obtained	20/07/2012	pH	6.6	6.5-8.5	
Published	1/08/2012	Suspended Solids	2	20	mg/L
Sampled	9/08/2012	Aluminium (Total)	0.09	0.1	mg/L
Obtained	22/08/2012	pH	6.6	6.5-8.5	
Published	31/08/2012	Suspended Solids	2	20	mg/L
Sampled	5/09/2012	Aluminium (Total)	0.05	0.1	mg/L
Obtained	11/09/2012	pH	6.7	6.5-8.5	
Published	14/09/2012	Suspended Solids	<1	20	mg/L