



## Copeton Water Treatment Plant

Sampling Point: Copeton Water Treatment Plant			EPL No. 4463		
Licence Period 20 September 2011 to 19 September 2012			Licensee: Inverell Shire Council		
<a href="http://www.environment.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4463&amp;id=4463&amp;option=licence&amp;searchrange=licence&amp;range=POEO%20licence&amp;prp=no&amp;status=Issued">http://www.environment.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4463&amp;id=4463&amp;option=licence&amp;searchrange=licence&amp;range=POEO licence&amp;prp=no&amp;status=Issued</a>			144 Otho Street, Inverell		
			Monitoring Frequency - Monthly		
		Quantity	Measurement	Limit	Units
Sampled	6/03/2012	Aluminium (Total)	0.057	0.1	mg/L
Reported	26/03/2012	pH	7.5	6.5-8.5	
Published	1/06/2012	Suspended Solids	<1	20	mg/L
Sampled	4/04/2012	Aluminium (Total)	0.029	0.1	mg/L
Reported	17/04/2012	pH	7.2	6.5-8.5	
Published	1/06/2012	Suspended Solids	15	20	mg/L
Sampled	1/05/2012	Aluminium (Total)	0.73	0.1	mg/L
Reported	9/05/2012	pH	6.4	6.5-8.5	
Published	1/06/2012	Suspended Solids	6	20	mg/L
Sampled	19/06/2012	Aluminium (Total)	0.039	0.1	mg/L
Reported	27/06/2012	pH	7.2	6.5-8.5	
Published	3/07/2012	Suspended Solids	3	20	mg/L
Sampled	10/07/2012	Aluminium (Total)	0.031	0.1	mg/L
Reported	20/07/2012	pH	7	6.5-8.5	
Published	1/08/2012	Suspended Solids	4	20	mg/L
Sampled	9/08/2012	Aluminium (Total)	0.039	0.1	mg/L
Reported	22/08/2012	pH	7.2	6.5-8.5	
Published	31/08/2012	Suspended Solids	3	20	mg/L
Sampled	5/09/2012	Aluminium (Total)	0.055	0.1	mg/L
Reported	11/09/2012	pH	6.9	6.5-8.5	
Published	14/09/2012	Suspended Solids	1	20	mg/L