



## Ashford Water Treatment Plant

Sampling Point: Ashford Water Treatment Plant			EPL No. 4412		
Licence Period 6 September 2014 to 5 September 2015			Licensee: Inverell Shire Council		
<a href="http://www.environment.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4412&amp;id=4412&amp;option=licence&amp;searchrange=licence&amp;range=POEO licence&amp;prp=no&amp;status=Issued">http://www.environment.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4412&amp;id=4412&amp;option=licence&amp;searchrange=licence&amp;range=POEO licence&amp;prp=no&amp;status=Issued</a>			144 Otho Street, Inverell		
			Monitoring Frequency - Monthly		
		Quantity	Measurement	Limit	Units
Sampled	7/10/2014	Aluminium (Total)	0.018	0.1	mg/L
Obtained	10/10/2014	pH	6.9	6.5-8.5	pH
Published	14/10/2014	Suspended Solids	5	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	3/11/2014	Aluminium (Total)	0.087	0.1	mg/L
Obtained	7/11/2014	pH	6.6	6.5-8.5	pH
Published	2/12/2014	Suspended Solids	8	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	2/12/2014	Aluminium (Total)	0.031	0.1	mg/L
Obtained	8/12/2014	pH	6.7	6.5-8.5	pH
Published	15/12/2014	Suspended Solids	9	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	6/01/2015	Aluminium (Total)	0.018	0.1	mg/L
Obtained	8/01/2015	pH	6.8	6.5-8.5	pH
Published	9/01/2015	Suspended Solids	9	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	3/02/2015	Aluminium (Total)	2.2	0.1	mg/L
Obtained	9/02/2015	pH	6.7	6.5-8.5	pH
Published	10/02/2015	Suspended Solids	14	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	3/03/2015	Aluminium (Total)	0.23	0.1	mg/L
Obtained	9/03/2015	pH	6.6	6.5-8.5	pH
Published	10/03/2015	Suspended Solids	11	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	14/04/2015	Aluminium (Total)	3	0.1	mg/L
Obtained	17/04/2015	pH	7	6.5-8.5	pH
Published	20/04/2015	Suspended Solids	22	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	5/05/2015	Aluminium (Total)	3.2	0.1	mg/L
Obtained	18/05/2015	pH	7.1	6.5-8.5	pH
Published	18/05/2015	Suspended Solids	4	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	2/06/2015	Aluminium (Total)	0.17	0.1	mg/L
Obtained	12/06/2015	pH	6.7	6.5-8.5	pH
Published	12/06/2015	Suspended Solids	8	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	7/07/2015	Aluminium (Total)	0.018	0.1	mg/L
Obtained	20/07/2015	pH	6.7	6.5-8.5	pH
Published	22/07/2015	Suspended Solids	6	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	5/08/2015	Aluminium (Total)	0.7	0.1	mg/L
Obtained	10/08/2015	pH	6.8	6.5-8.5	pH
Published	11/08/2015	Suspended Solids	6	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	2/09/2015	Aluminium (Total)	1.2	0.1	mg/L
Obtained	4/09/2015	pH	7	6.5-8.5	pH
Published	9/09/2015	Suspended Solids	15	20	mg/L