



Ashford Water Treatment Plant

Sampling Point: Ashford Water Treatment Plant

EPL No. 4412

Licence Period 6 September 2015 to 5 September 2016

Licensee: Inverell Shire Council

<http://www.environment.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4412&id=4412&option=licence&searchrange=licence&range=POEO licence&prp=no&status=Issued>

144 Otho Street, Inverell

Monitoring Frequency - Monthly

		Quantity	Measurement	Limit	Units
Sampled	14/10/2015	Aluminium (Total)	0.025	0.1	mg/L
Obtained	14/10/2015	pH	6.7	6.5-8.5	pH
Published	23/10/2015	Suspended Solids	10	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	11/11/2015	Aluminium (Total)	1.1	0.1	mg/L
Obtained	11/11/2015	pH	6.5	6.5-8.5	pH
Published	16/11/2015	Suspended Solids	22	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	2/12/2015	Aluminium (Total)	0.2	0.1	mg/L
Obtained	8/12/2015	pH	7.4	6.5-8.5	pH
Published	9/12/2015	Suspended Solids	3	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	12/01/2016	Aluminium (Total)	0.34	0.1	mg/L
Obtained	18/01/2016	pH	6.8	6.5-8.5	pH
Published	22/01/2016	Suspended Solids	<1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	2/02/2016	Aluminium (Total)	2.6	0.1	mg/L
Obtained	8/02/2016	pH	7	6.5-8.5	pH
Published	8/02/2016	Suspended Solids	18	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	1/03/2016	Aluminium (Total)	0.055	0.1	mg/L
Obtained	7/03/2016	pH	6.9	6.5-8.5	pH
Published	8/03/2016	Suspended Solids	6	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	5/04/2016	Aluminium (Total)	0.049	0.1	mg/L
Obtained	11/04/2016	pH	7.1	6.5-8.5	pH
Published	14/04/2016	Suspended Solids	<1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	3/05/2016	Aluminium (Total)	0.039	0.1	mg/L
Obtained	10/05/2016	pH	7.1	6.5-8.5	pH
Published	12/05/2016	Suspended Solids	<1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	7/06/2016	Aluminium (Total)	0.11	0.1	mg/L
Obtained	14/06/2016	pH	7	6.5-8.5	pH
Published	16/06/2016	Suspended Solids	4	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	5/07/2016	Aluminium (Total)	5.7	0.1	mg/L
Obtained	13/07/2016	pH	7.2	6.5-8.5	pH
Published	19/07/2016	Suspended Solids	17	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	2/08/2016	Aluminium (Total)	0.11	0.1	mg/L
Obtained	12/08/2016	pH	7.2	6.5-8.5	pH

Published	25/08/2016	Suspended Solids	3	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	6/09/2016	Aluminium (Total)	2.22	0.1	mg/L
Obtained	14/09/2016	pH	6.8	6.5-8.5	pH
Published	15/09/2016	Suspended Solids	2	20	mg/L