



Ashford Water Treatment Plant

Sampling Point: Ashford Water Treatment Plant

EPL No. 4412

Licence Period 6 September 2016 to 5 September 2017

Licensee: Inverell Shire Council

<http://www.environment.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4412&id=4412&option=licence&searchrange=licence&range=POEO licence&prp=no&status=Issued>

144 Otho Street, Inverell

Monitoring Frequency - Monthly

		Quantity	Measurement	Limit	Units
Sampled	11/10/2016	Aluminium (Total)	0.69	0.1	mg/L
Obtained	17/10/2016	pH	6.6	6.5-8.5	pH
Published	20/10/2016	Suspended Solids	9	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	8/11/2016	Aluminium (Total)	0.074	0.1	mg/L
Obtained	11/11/2016	pH	6.8	6.5-8.5	pH
Published	21/12/2016	Suspended Solids	6	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	13/12/2016	Aluminium (Total)	0.13	0.1	mg/L
Obtained	20/12/2016	pH	7.2	6.5-8.5	pH
Published	23/12/2016	Suspended Solids	7	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	10/01/2017	Aluminium (Total)	0.15	0.1	mg/L
Obtained	16/01/2017	pH	7.2	6.5-8.5	pH
Published	19/01/2017	Suspended Solids	6	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	7/02/2017	Aluminium (Total)	0.22	0.1	mg/L
Obtained	17/02/2017	pH	7	6.5-8.5	pH
Published	21/02/2017	Suspended Solids	6	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	7/03/2017	Aluminium (Total)	0.024	0.1	mg/L
Obtained	20/03/2017	pH	6.7	6.5-8.5	pH
Published	22/03/2017	Suspended Solids	4	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	4/04/2017	Aluminium (Total)	1.09	0.1	mg/L
Obtained	18/04/2017	pH	6.9	6.5-8.5	pH
Published	20/04/2017	Suspended Solids	5	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	2/05/2017	Aluminium (Total)	1.3	0.1	mg/L
Obtained	9/05/2017	pH	6.9	6.5-8.5	pH
Published	26/05/2017	Suspended Solids	8	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	6/06/2017	Aluminium (Total)	0.81	0.1	mg/L
Obtained	19/06/2017	pH	6.9	6.5-8.5	pH
Published	20/06/2017	Suspended Solids	14	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	3/07/2017	Aluminium (Total)	1.1	0.1	mg/L
Obtained	13/07/2017	pH	6.8	6.5-8.5	pH
Published	24/07/2017	Suspended Solids	8	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	1/08/2017	Aluminium (Total)	0.11	0.1	mg/L
Obtained	7/08/2017	pH	6.8	6.5-8.5	pH

Published	10/08/2017	Suspended Solids	6	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	5/09/2017	Aluminium (Total)	0.078	0.1	mg/L
Obtained	18/09/2017	pH	6.8	6.5-8.5	pH
Published	18/09/2017	Suspended Solids	6	20	mg/L