



Copeton Water Treatment Plant

Sampling Point: Copeton Water Treatment Plant			EPL No. 4463		
Licence Period 20 September 2014 to 19 September 2015			Licensee: Inverell Shire Council		
http://www.environment.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4463&id=4463&option=licence&searchrange=licence&range=POEO licence&prp=no&status=Issued			144 Otho Street, Inverell		
			Monitoring Frequency - Monthly		
		Quantity	Measurement	Limit	Units
Sampled	7/10/2014	Aluminium (Total)	0.083	0.1	mg/L
Reported	10/10/2014	pH	7.3	6.5-8.5	
Published	14/10/2014	Suspended Solids	<1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	3/11/2014	Aluminium (Total)	0.19	0.1	mg/L
Reported	7/11/2014	pH	6.7	6.5-8.5	
Published	2/12/2014	Suspended Solids	2	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	2/12/2014	Aluminium (Total)	0.13	0.1	mg/L
Reported	8/12/2014	pH	6.8	6.5-8.5	
Published	15/12/2014	Suspended Solids	3	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	3/02/2015	Aluminium (Total)	0.35	0.1	mg/L
Reported	9/02/2015	pH	7.1	6.5-8.5	
Published	10/02/2015	Suspended Solids	7	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	3/03/2015	Aluminium (Total)	0.36	0.1	mg/L
Reported	9/03/2015	pH	7	6.5-8.5	
Published	10/03/2015	Suspended Solids	3	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	14/04/2015	Aluminium (Total)	0.21	0.1	mg/L
Reported	17/04/2015	pH	6.9	6.5-8.5	
Published	20/04/2015	Suspended Solids	3	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	5/05/2015	Aluminium (Total)	0.075	0.1	mg/L
Reported	18/05/2015	pH	7.2	6.5-8.5	
Published	18/05/2015	Suspended Solids	<1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	2/06/2015	Aluminium (Total)	0.24	0.1	mg/L
Reported	12/06/2015	pH	7	6.5-8.5	
Published	12/06/2015	Suspended Solids	2	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	7/07/2015	Aluminium (Total)	0.1	0.1	mg/L
Reported	20/07/2015	pH	7	6.5-8.5	
Published	22/07/2015	Suspended Solids	<1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	5/08/2015	Aluminium (Total)	0.12	0.1	mg/L
Reported	10/08/2015	pH	7	6.5-8.5	
Published	11/08/2015	Suspended Solids	<1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	2/09/2015	Aluminium (Total)	0.56	0.1	mg/L
Reported	4/09/2015	pH	7.4	6.5-8.5	
Published	9/09/2015	Suspended Solids	5	20	mg/L