



Copeton Water Treatment Plant

Sampling Point: Copeton Water Treatment Plant			EPL No. 4463		
Licence Period 20 September 2015 to 19 September 2016			Licensee: Inverell Shire Council		
http://www.environment.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4463&id=4463&option=licence&searchrange=licence&range=POEO licence&prp=no&status=Issued			144 Otho Street, Inverell		
			Monitoring Frequency - Monthly		
		Quantity	Measurement	Limit	Units
Sampled	14/10/2015	Aluminium (Total)	0.17	0.1	mg/L
Reported	14/10/2015	pH	7	6.5-8.5	
Published	23/10/2015	Suspended Solids	2	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	11/11/2015	Aluminium (Total)	0.84	0.1	mg/L
Reported	11/11/2015	pH	6.9	6.5-8.5	
Published	16/11/2015	Suspended Solids	6	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	2/12/2015	Aluminium (Total)	0.2	0.1	mg/L
Reported	8/12/2015	pH	7.7	6.5-8.5	
Published	9/12/2015	Suspended Solids	<1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	12/01/2016	Aluminium (Total)	0.6	0.1	mg/L
Reported	18/01/2016	pH	7	6.5-8.5	
Published	22/01/2016	Suspended Solids	7	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	2/02/2016	Aluminium (Total)	3.4	0.1	mg/L
Reported	12/02/2016	pH	6.7	6.5-8.5	
Published	16/02/2016	Suspended Solids	24	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	1/03/2016	Aluminium (Total)	0.74	0.1	mg/L
Reported	7/03/2016	pH	6.8	6.5-8.5	
Published	8/03/2016	Suspended Solids	12	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	5/04/2016	Aluminium (Total)	0.38	0.1	mg/L
Reported	11/04/2016	pH	7.2	6.5-8.5	
Published	14/04/2016	Suspended Solids	<1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	3/05/2016	Aluminium (Total)	0.042	0.1	mg/L
Reported	10/05/2016	pH	7.1	6.5-8.5	
Published	12/05/2016	Suspended Solids	<1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	7/06/2016	Aluminium (Total)	0.43	0.1	mg/L
Reported	14/06/2016	pH	7	6.5-8.5	
Published	16/06/2016	Suspended Solids	3	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	5/07/2016	Aluminium (Total)	0.82	0.1	mg/L
Reported	13/07/2016	pH	7.2	6.5-8.5	
Published	20/07/2016	Suspended Solids	9	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	2/08/2016	Aluminium (Total)	0.18	0.1	mg/L
Reported	12/08/2016	pH	7.4	6.5-8.5	

Published	25/08/2016	Suspended Solids	3	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	6/09/2016	Aluminium (Total)	0.94	0.1	mg/L
Reported	14/09/2016	pH	6.9	6.5-8.5	
Published	15/09/2016	Suspended Solids	6	20	mg/L