



Copeton Water Treatment Plant

Sampling Point: Copeton Water Treatment Plant			EPL No. 4463		
Licence Period 20 September 2016 to 19 September 2017			Licensee: Inverell Shire Council		
http://www.environment.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4463&id=4463&option=licence&searchrange=licence&range=POEO licence&prp=no&status=Issued			144 Otho Street, Inverell		
			Monitoring Frequency - Monthly		
		Quantity	Measurement	Limit	Units
Sampled	11/10/2016	Aluminium (Total)	0.16	0.1	mg/L
Reported	17/10/2016	pH	6.7	6.5-8.5	
Published	20/10/2016	Suspended Solids	3	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	8/11/2016	Aluminium (Total)	0.14	0.1	mg/L
Reported	11/11/2016	pH	6.9	6.5-8.5	
Published	21/12/2016	Suspended Solids	2	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	13/12/2016	Aluminium (Total)	0.12	0.1	mg/L
Reported	20/12/2016	pH	6.8	6.5-8.5	
Published	23/12/2016	Suspended Solids	<1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	10/01/2017	Aluminium (Total)	0.039	0.1	mg/L
Reported	16/01/2017	pH	7.1	6.5-8.5	
Published	19/01/2017	Suspended Solids	1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	7/02/2017	Aluminium (Total)	0.051	0.1	mg/L
Reported	17/02/2017	pH	6.9	6.5-8.5	
Published	22/02/2017	Suspended Solids	1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	7/03/2017	Aluminium (Total)	0.15	0.1	mg/L
Reported	20/03/2017	pH	6.7	6.5-8.5	
Published	22/03/2017	Suspended Solids	10	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	4/04/2017	Aluminium (Total)	0.14	0.1	mg/L
Reported	18/04/2017	pH	7.2	6.5-8.5	
Published	20/04/2017	Suspended Solids	<1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	2/05/2017	Aluminium (Total)	1.4	0.1	mg/L
Reported	9/05/2017	pH	7.3	6.5-8.5	
Published	26/05/2017	Suspended Solids	11	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	6/06/2017	Aluminium (Total)	0.35	0.1	mg/L
Reported	19/06/2017	pH	7.1	6.5-8.5	
Published	20/06/2017	Suspended Solids	3	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	3/07/2017	Aluminium (Total)	0.29	0.1	mg/L
Reported	13/07/2017	pH	7	6.5-8.5	
Published	24/07/2017	Suspended Solids	5	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	1/08/2017	Aluminium (Total)	0.066	0.1	mg/L
Reported	7/08/2017	pH	7	6.5-8.5	

Published	10/08/2017	Suspended Solids	3	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	5/09/2017	Aluminium (Total)	1.98	0.1	mg/L
Reported	18/09/2017	pH	6.9	6.5-8.5	
Published	18/09/2017	Suspended Solids	11	20	mg/L