



# Ashford Water Treatment Plant

**Sampling Point: Ashford Water Treatment Plant**

**EPL No. 4412**

**Licence Period 6 September 2012 to 5 September 2013**

**Licensee: Inverell Shire Council**

<http://www.environment.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4412&id=4412&option=licence&searchrange=licence&range=POEO licence&prp=no&status=Issued>

**144 Otho Street, Inverell**

**Monitoring Frequency - Monthly**

		Quantity	Measurement	Limit	Units
Sampled	2/10/2012	Aluminium (Total)	0.039	0.1	mg/L
Obtained	9/10/2012	pH	7	6.5-8.5	pH
Published	19/10/2012	Suspended Solids	1	20	mg/L
Sampled	13/11/2012	Aluminium (Total)	0.39	0.1	mg/L
Obtained	26/11/2012	pH	6.8	6.5-8.5	pH
Published	28/11/2012	Suspended Solids	<1	20	mg/L
Sampled	4/12/2012	Aluminium (Total)	0.026	0.1	mg/L
Obtained	12/12/2012	pH	6.7	6.5-8.5	pH
Published	19/12/2012	Suspended Solids	18	20	mg/L
Sampled	8/01/2013	Aluminium (Total)	3.3	0.1	mg/L
Obtained	15/01/2013	pH	6.9	6.5-8.5	pH
Published	20/02/2013	Suspended Solids	27	20	mg/L
Sampled	5/02/2013	Aluminium (Total)	1.5	0.1	mg/L
Obtained	11/02/2013	pH	6.8	6.5-8.5	pH
Published	20/02/2013	Suspended Solids	19	20	mg/L
Sampled	5/03/2013	Aluminium (Total)	2.8	0.1	mg/L
Obtained	8/03/2013	pH	6.7	6.5-8.5	pH
Published	13/03/2013	Suspended Solids	24	20	mg/L
Sampled	9/04/2013	Aluminium (Total)	0.031	0.1	mg/L
Obtained	15/04/2013	pH	6.7	6.5-8.5	pH
Published	16/04/2013	Suspended Solids	4	20	mg/L
Sampled	7/05/2013	Aluminium (Total)	0.025	0.1	mg/L
Obtained	10/05/2013	pH	6.8	6.5-8.5	pH
Published	14/05/2013	Suspended Solids	4	20	mg/L
Sampled	12/06/2013	Aluminium (Total)	1.8	0.1	mg/L
Obtained	25/06/2013	pH	6.7	6.5-8.5	pH
Published	27/06/2013	Suspended Solids	6	20	mg/L
Sampled	2/07/2013	Aluminium (Total)	1.6	0.1	mg/L
Obtained	8/07/2013	pH	6.8	6.5-8.5	pH
Published	11/07/2013	Suspended Solids	3	20	mg/L
Sampled	6/08/2013	Aluminium (Total)	0.04	0.1	mg/L
Obtained	19/08/2013	pH	6.8	6.5-8.5	pH
Published	26/08/2013	Suspended Solids	5	20	mg/L
Sampled	3/09/2013	Aluminium (Total)	0.022	0.1	mg/L
Obtained	11/09/2013	pH	6.9	6.5-8.5	pH
Published	19/09/2013	Suspended Solids	4	20	mg/L