



# Copeton Water Treatment Plant

Sampling Point: Copeton Water Treatment Plant			EPL No. 4463		
Licence Period 20 September 2012 to 19 September 2013			Licensee: Inverell Shire Council		
<a href="http://www.environment.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4463&amp;id=4463&amp;option=licence&amp;searchrange=licence&amp;range=POEO%20licence&amp;prp=no&amp;status=Issued">http://www.environment.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4463&amp;id=4463&amp;option=licence&amp;searchrange=licence&amp;range=POEO licence&amp;prp=no&amp;status=Issued</a>			144 Otho Street, Inverell		
			Monitoring Frequency - Monthly		
		Quantity	Measurement	Limit	Units
Sampled	2/10/2012	Aluminium (Total)	0.1	0.1	mg/L
Reported	9/10/2012	pH	7	6.5-8.5	
Published	19/10/2012	Suspended Solids	3	20	mg/L
Sampled	13/11/2012	Aluminium (Total)	0.057	0.1	mg/L
Reported	26/11/2012	pH	7.1	6.5-8.5	
Published	28/11/2012	Suspended Solids	<1	20	mg/L
Sampled	4/12/2012	Aluminium (Total)	0.12	0.1	mg/L
Reported	12/12/2012	pH	6.8	6.5-8.5	
Published	19/12/2012	Suspended Solids	5	20	mg/L
Sampled	8/01/2013	Aluminium (Total)	0.15	0.1	mg/L
Reported	15/01/2013	pH	6.7	6.5-8.5	
Published	20/02/2013	Suspended Solids	12	20	mg/L
Sampled	5/02/2013	Aluminium (Total)	0.099	0.1	mg/L
Reported	11/02/2013	pH	6.7	6.5-8.5	
Published	20/02/2013	Suspended Solids	6	20	mg/L
Sampled	5/03/2013	Aluminium (Total)	0.12	0.1	mg/L
Reported	8/03/2013	pH	6.7	6.5-8.5	
Published	13/03/2013	Suspended Solids	5	20	mg/L
Sampled	9/04/2013	Aluminium (Total)	0.034	0.1	mg/L
Reported	15/04/2013	pH	6.7	6.5-8.5	
Published	16/04/2013	Suspended Solids	5	20	mg/L
Sampled	7/05/2013	Aluminium (Total)	0.06	0.1	mg/L
Reported	10/05/2013	pH	6.9	6.5-8.5	
Published	14/05/2013	Suspended Solids	<1	20	mg/L
Sampled	12/06/2013	Aluminium (Total)	0.095	0.1	mg/L
Reported	25/06/2013	pH	6.7	6.5-8.5	
Published	27/06/2013	Suspended Solids	1	20	mg/L
Sampled	2/07/2013	Aluminium (Total)	0.12	0.1	mg/L
Reported	8/07/2013	pH	6.8	6.5-8.5	
Published	10/07/2013	Suspended Solids	5	20	mg/L
Sampled	6/08/2013	Aluminium (Total)	0.043	0.1	mg/L
Reported	19/08/2013	pH	6.7	6.5-8.5	
Published	26/08/2013	Suspended Solids	4	20	mg/L
Sampled	3/09/2013	Aluminium (Total)	0.095	0.1	mg/L
Reported	11/09/2013	pH	6.8	6.5-8.5	
Published	19/09/2013	Suspended Solids	31	20	mg/L