



Ashford Water Treatment Plant

Sampling Point: Ashford Water Treatment Plant

EPL No. 4412

Licence Period 6 September 2013 to 5 September 2014

Licensee: Inverell Shire Council

<http://www.environment.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4412&id=4412&option=licence&searchrange=licence&range=POEO licence&prp=no&status=Issued>

144 Otho Street, Inverell

Monitoring Frequency - Monthly

		Quantity	Measurement	Limit	Units
Sampled	15/10/2013	Aluminium (Total)	0.016	0.1	mg/L
Obtained	21/10/2013	pH	6.8	6.5-8.5	pH
Published	25/10/2013	Suspended Solids	7	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	6/11/2013	Aluminium (Total)	0.02	0.1	mg/L
Obtained	18/11/2013	pH	6.8	6.5-8.5	pH
Published	19/11/2013	Suspended Solids	7	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	3/12/2013	Aluminium (Total)	0.028	0.1	mg/L
Obtained	11/12/2013	pH	6.8	6.5-8.5	pH
Published	13/12/2013	Suspended Solids	6	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	14/01/2014	Aluminium (Total)	0.019	0.1	mg/L
Obtained	22/01/2014	pH	7	6.5-8.5	pH
Published	24/01/2014	Suspended Solids	7	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	4/02/2014	Aluminium (Total)	0.05	0.1	mg/L
Obtained	10/02/2014	pH	6.7	6.5-8.5	pH
Published	18/02/2014	Suspended Solids	7	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	4/03/2014	Aluminium (Total)	0.016	0.1	mg/L
Obtained	17/03/2014	pH	6.7	6.5-8.5	pH
Published	21/03/2014	Suspended Solids	5	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	1/04/2014	Aluminium (Total)	0.59	0.1	mg/L
Obtained	7/04/2014	pH	6.6	6.5-8.5	pH
Published	11/04/2014	Suspended Solids	15	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	6/05/2014	Aluminium (Total)	0.024	0.1	mg/L
Obtained	12/05/2014	pH	6.8	6.5-8.5	pH
Published	6/06/2014	Suspended Solids	7	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	3/06/2014	Aluminium (Total)	0.017	0.1	mg/L
Obtained	18/06/2014	pH	6.6	6.5-8.5	pH
Published	20/06/2014	Suspended Solids	2	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	1/07/2014	Aluminium (Total)	0.022	0.1	mg/L
Obtained	8/07/2014	pH	6.5	6.5-8.5	pH
Published	9/07/2014	Suspended Solids	<1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	1/07/2014	Aluminium (Total)	0.022	0.1	mg/L
Obtained	8/07/2014	pH	6.5	6.5-8.5	pH

Published	9/07/2014	Suspended Solids	<1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	5/08/2014	Aluminium (Total)	0.015	0.1	mg/L
Obtained	15/08/2014	pH	7	6.5-8.5	pH
Published	19/08/2014	Suspended Solids	2	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	2/09/2014	Aluminium (Total)	0.031	0.1	mg/L
Obtained	12/09/2014	pH	7.5	6.5-8.5	pH
Published	23/09/2014	Suspended Solids	5	20	mg/L