



# Copeton Water Treatment Plant

Sampling Point: Copeton Water Treatment Plant			EPL No. 4463		
Licence Period 20 September 2013 to 19 September 2014			Licensee: Inverell Shire Council		
<a href="http://www.environment.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4463&amp;id=4463&amp;option=licence&amp;searchrange=licence&amp;range=POEO%20licence&amp;prp=no&amp;status=Issued">http://www.environment.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4463&amp;id=4463&amp;option=licence&amp;searchrange=licence&amp;range=POEO licence&amp;prp=no&amp;status=Issued</a>			144 Otho Street, Inverell		
			Monitoring Frequency - Monthly		
		Quantity	Measurement	Limit	Units
Sampled	15/10/2013	Aluminium (Total)	0.063	0.1	mg/L
Reported	21/10/2013	pH	6.8	6.5-8.5	
Published	25/10/2013	Suspended Solids	2	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	6/11/2013	Aluminium (Total)	0.13	0.1	mg/L
Reported	18/11/2013	pH	7	6.5-8.5	
Published	19/11/2013	Suspended Solids	2	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	3/12/2013	Aluminium (Total)	0.071	0.1	mg/L
Reported	11/12/2013	pH	7.1	6.5-8.5	
Published	13/12/2013	Suspended Solids	<1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	14/01/2014	Aluminium (Total)	0.36	0.1	mg/L
Reported	22/01/2014	pH	7.4	6.5-8.5	
Published	24/01/2014	Suspended Solids	7	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	4/02/2014	Aluminium (Total)	0.16	0.1	mg/L
Reported	10/02/2014	pH	7.1	6.5-8.5	
Published	18/02/2014	Suspended Solids	2	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	4/03/2014	Aluminium (Total)	0.086	0.1	mg/L
Reported	17/03/2014	pH	7.2	6.5-8.5	
Published	21/03/2014	Suspended Solids	3	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	1/04/2014	Aluminium (Total)	0.11	0.1	mg/L
Reported	7/04/2014	pH	6.9	6.5-8.5	
Published	11/04/2014	Suspended Solids	3	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	6/05/2014	Aluminium (Total)	0.15	0.1	mg/L
Reported	12/05/2014	pH	7.1	6.5-8.5	
Published	6/06/2014	Suspended Solids	2	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	3/06/2014	Aluminium (Total)	0.21	0.1	mg/L
Reported	18/06/2014	pH	6.9	6.5-8.5	
Published	20/06/2014	Suspended Solids	2	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	1/07/2014	Aluminium (Total)	0.2	0.1	mg/L
Reported	8/07/2014	pH	6.8	6.5-8.5	
Published	9/07/2014	Suspended Solids	2	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	5/08/2014	Aluminium (Total)	0.098	0.1	mg/L
Reported	15/08/2014	pH	7.2	6.5-8.5	

Published	19/08/2014	Suspended Solids	2	20	mg/L
		<b>Quantity</b>	<b>Measurement</b>	<b>Limit</b>	<b>Units</b>
Sampled	2/09/2014	Aluminium (Total)	0.11	0.1	mg/L
Reported	12/09/2014	pH	7.5	6.5-8.5	
Published	23/09/2014	Suspended Solids	3	20	mg/L