



# Ashford Water Treatment Plant

**Sampling Point: Ashford Water Treatment Plant**

**EPL No. 4412**

**Licence Period 6 September 2017 to 5 September 2018**

**Licensee: Inverell Shire Council**

[http://www.environment.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4412&id=4412&option=licence&searchrange=licence&range=POEO licence&prp=no&status=Issued](http://www.environment.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4412&id=4412&option=licence&searchrange=licence&range=POEO%20licence&prp=no&status=Issued)

**144 Otho Street, Inverell**

**Monitoring Frequency - Monthly**

		<b>Quantity</b>	<b>Measurement</b>	<b>Limit</b>	<b>Units</b>
Sampled	10.10.2017	Aluminium (Total)	0.71	0.1	mg/L
Obtained	24.10.2017	pH	6.8	6.5-8.5	pH
Published	31.10.2017	Suspended Solids	7	20	mg/L
		<b>Quantity</b>	<b>Measurement</b>	<b>Limit</b>	<b>Units</b>
Sampled	14.11.2017	Aluminium (Total)	0.38	0.1	mg/L
Obtained	20.11.2017	pH	6.6	6.5-8.5	pH
Published	24.11.2017	Suspended Solids	13	20	mg/L
		<b>Quantity</b>	<b>Measurement</b>	<b>Limit</b>	<b>Units</b>
Sampled	05.12.2017	Aluminium (Total)	0.061	0.1	mg/L
Obtained	14.12.2017	pH	6.5	6.5-8.5	pH
Published	19.12.2017	Suspended Solids	6	20	mg/L
		<b>Quantity</b>	<b>Measurement</b>	<b>Limit</b>	<b>Units</b>
Sampled	09.01.2018	Aluminium (Total)	0.066	0.1	mg/L
Obtained	19.01.2018	pH	6.5	6.5-8.5	pH
Published	16.02.2018	Suspended Solids	10	20	mg/L
		<b>Quantity</b>	<b>Measurement</b>	<b>Limit</b>	<b>Units</b>
Sampled	06.02.2018	Aluminium (Total)	0.11	0.1	mg/L
Obtained	13.02.2018	pH	6.6	6.5-8.5	pH
Published	19.02.2018	Suspended Solids	12	20	mg/L
		<b>Quantity</b>	<b>Measurement</b>	<b>Limit</b>	<b>Units</b>
Sampled	06.03.2018	Aluminium (Total)	0.22	0.1	mg/L
Obtained	14.03.2018	pH	6.5	6.5-8.5	pH
Published	16.03.2018	Suspended Solids	12	20	mg/L
		<b>Quantity</b>	<b>Measurement</b>	<b>Limit</b>	<b>Units</b>
Sampled	10.04.2018	Aluminium (Total)	0.11	0.1	mg/L
Obtained	13.04.2018	pH	6.7	6.5-8.5	pH
Published	20.04.2018	Suspended Solids	11	20	mg/L
		<b>Quantity</b>	<b>Measurement</b>	<b>Limit</b>	<b>Units</b>
Sampled	01.05.2018	Aluminium (Total)	0.075	0.1	mg/L
Obtained	04.05.2018	pH	6.9	6.5-8.5	pH
Published	09.05.2018	Suspended Solids	6	20	mg/L
		<b>Quantity</b>	<b>Measurement</b>	<b>Limit</b>	<b>Units</b>
Sampled	05.06.2018	Aluminium (Total)	0.075	0.1	mg/L
Obtained	13.06.2018	pH	6.5	6.5-8.5	pH
Published	14.06.2018	Suspended Solids	6	20	mg/L
		<b>Quantity</b>	<b>Measurement</b>	<b>Limit</b>	<b>Units</b>
Sampled	03.07.2018	Aluminium (Total)	0.54	0.1	mg/L
Obtained	13.07.2018	pH	6.6	6.5-8.5	pH
Published	23.07.2018	Suspended Solids	12	20	mg/L
		<b>Quantity</b>	<b>Measurement</b>	<b>Limit</b>	<b>Units</b>
Sampled	07.08.2018	Aluminium (Total)	0.053	0.1	mg/L
Obtained	21.08.2018	pH	6.7	6.5-8.5	pH

Published	21.08.2018	Suspended Soilds	7	20	mg/L
		<b>Quantity</b>	<b>Measurement</b>	<b>Limit</b>	<b>Units</b>
Sampled	04.09.2018	Aluminium (Total)	3.76	0.1	mg/L
Obtained	12.09.2018	pH	6.6	6.5-8.5	pH
Published	17.09.2018	Suspended Soilds	7	20	mg/L