



Copeton Water Treatment Plant

Sampling Point: Copeton Water Treatment Plant			EPL No. 4463		
Licence Period 20 September 2017 to 19 September 2018			Licensee: Inverell Shire Council		
http://www.environment.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4463&id=4463&option=licence&searchrange=licence&range=POEO licence&prp=no&status=Issued			144 Otho Street, Inverell		
			Monitoring Frequency - Monthly		
		Quantity	Measurement	Limit	Units
Sampled	10.10.2017	Aluminium (Total)	0.33	0.1	mg/L
Reported	24.10.2017	pH	7	6.5-8.5	
Published	31.10.2017	Suspended Solids	4	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	14.11.2017	Aluminium (Total)	0.13	0.1	mg/L
Reported	20.11.2017	pH	6.7	6.5-8.5	
Published	24.11.2017	Suspended Solids	2	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	05.12.2017	Aluminium (Total)	0.14	0.1	mg/L
Reported	14.12.2017	pH	6.6	6.5-8.5	
Published	19.12.2017	Suspended Solids	<1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	09.01.2018	Aluminium (Total)	0.077	0.1	mg/L
Reported	19.01.2018	pH	6.8	6.5-8.5	
Published	16.02.2018	Suspended Solids	<1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	06.02.2018	Aluminium (Total)	0.086	0.1	mg/L
Reported	13.02.2018	pH	7.2	6.5-8.5	
Published	19.02.2018	Suspended Solids	5	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	06.03.2018	Aluminium (Total)	0.19	0.1	mg/L
Reported	14.03.2018	pH	6.7	6.5-8.5	
Published	16.03.2018	Suspended Solids	5	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	10.04.2018	Aluminium (Total)	0.088	0.1	mg/L
Reported	13.04.2018	pH	7	6.5-8.5	
Published	20.04.2018	Suspended Solids	2	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	01.05.2018	Aluminium (Total)	0.063	0.1	mg/L
Reported	04.05.2018	pH	7	6.5-8.5	
Published	09.05.2018	Suspended Solids	2	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	05.06.2018	Aluminium (Total)	0.061	0.1	mg/L
Reported	13.06.2018	pH	6.8	6.5-8.5	
Published	14.06.2018	Suspended Solids	1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	03.07.2018	Aluminium (Total)	0.2	0.1	mg/L
Reported	13.07.2018	pH	6.5	6.5-8.5	
Published	23.07.2018	Suspended Solids	2	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	07.08.2018	Aluminium (Total)	0.075	0.1	mg/L
Reported	21.08.2018	pH	6.8	6.5-8.5	

Published	21.08.2018	Suspended Soilds	<1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	04.09.2018	Aluminium (Total)	0.09	0.1	mg/L
Reported	12.09.2018	pH	6.6	6.5-8.5	
Published	17.09.2018	Suspended Soilds	<1	20	mg/L