



Ashford Water Treatment Plant

Sampling Point: Ashford Water Treatment Plant

EPL No. 4412

Licence Period 6 September 2018 to 5 September 2019

Licensee: Inverell Shire Council

<http://www.environment.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4412&id=4412&option=licence&searchrange=licence&range=POEO licence&prp=no&status=Issued>

144 Otho Street, Inverell

Monitoring Frequency - Monthly

		Quantity	Measurement	Limit	Units
Sampled	9/10/2018	Aluminium (Total)	0.1	0.1	mg/L
Obtained	19/10/2018	pH	6.3	6.5-8.5	pH
Published	22/10/2018	Suspended Solids	11	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	13/11/2018	Aluminium (Total)	0.098	0.1	mg/L
Obtained	23/11/2018	pH	6.4	6.5-8.5	pH
Published	27/11/2018	Suspended Solids	6	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	4/12/2018	Aluminium (Total)	0.019	0.1	mg/L
Obtained	17/12/2018	pH	6.5	6.5-8.5	pH
Published	18/12/2018	Suspended Solids	14	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	8/01/2019	Aluminium (Total)	0.039	0.1	mg/L
Obtained	21/01/2019	pH	6.5	6.5-8.5	pH
Published	29/01/2019	Suspended Solids	29	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	5/02/2019	Aluminium (Total)	0.038	0.1	mg/L
Obtained	11/02/2019	pH	6.3	6.5-8.5	pH
Published	18/02/2019	Suspended Solids	11	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	5/03/2019	Aluminium (Total)	0.04	0.1	mg/L
Obtained	18/03/2019	pH	6.3	6.5-8.5	pH
Published	19/03/2019	Suspended Solids	14	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	2/04/2019	Aluminium (Total)	0.47	0.1	mg/L
Obtained	12/04/2019	pH	6.5	6.5-8.5	pH
Published	15/04/2019	Suspended Solids	11	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	7/05/2019	Aluminium (Total)	0.02	0.1	mg/L
Obtained	20/05/2019	pH	6.4	6.5-8.5	pH
Published	20/05/2019	Suspended Solids	8	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	4/06/2019	Aluminium (Total)	<0.005	0.1	mg/L
Obtained	17/06/2019	pH	6.6	6.5-8.5	pH
Published	18/06/2019	Suspended Solids	11	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	2/07/2019	Aluminium (Total)	<0.01	0.1	mg/L
Obtained	10/07/2019	pH	7.2	6.5-8.5	pH
Published	12/07/2019	Suspended Solids	3	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	6/08/2019	Aluminium (Total)	<0.01	0.1	mg/L
Obtained	15/08/2019	pH	7.2	6.5-8.5	pH

Published	21/08/2019	Suspended Soilds	<2	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	3/09/2019	Aluminium (Total)	0.03	0.1	mg/L
Obtained	11/09/2019	pH	7.3	6.5-8.5	pH
Published	18/09/2019	Suspended Soilds	5	20	mg/L