



Copeton Water Treatment Plant

Sampling Point: Copeton Water Treatment Plant			EPL No. 4463		
Licence Period 20 September 2018 to 19 September 2019			Licensee: Inverell Shire Council		
http://www.environment.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4463&id=4463&option=licence&searchrange=licence&range=POEO licence&prp=no&status=Issued			144 Otho Street, Inverell		
			Monitoring Frequency - Monthly		
		Quantity	Measurement	Limit	Units
Sampled	9/10/2018	Aluminium (Total)	0.094	0.1	mg/L
Reported	19/10/2018	pH	6.6	6.5-8.5	
Published	22/10/2018	Suspended Solids	6	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	13/11/2018	Aluminium (Total)	0.074	0.1	mg/L
Reported	23/11/2018	pH	6.7	6.5-8.5	
Published	27/11/2018	Suspended Solids	<1	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	4/12/2018	Aluminium (Total)	0.41	0.1	mg/L
Reported	17/12/2018	pH	6.6	6.5-8.5	
Published	18/12/2018	Suspended Solids	12	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	8/01/2019	Aluminium (Total)	0.078	0.1	mg/L
Reported	21/01/2019	pH	6.9	6.5-8.5	
Published	29/01/2019	Suspended Solids	6	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	5/02/2019	Aluminium (Total)	0.067	0.1	mg/L
Reported	11/02/2019	pH	6.7	6.5-8.5	
Published	18/02/2019	Suspended Solids	7	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	5/03/2019	Aluminium (Total)	0.42	0.1	mg/L
Reported	18/03/2019	pH	6.9	6.5-8.5	
Published	19/03/2019	Suspended Solids	9	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	2/04/2019	Aluminium (Total)	0.51	0.1	mg/L
Reported	12/04/2019	pH	7	6.5-8.5	
Published	15/04/2019	Suspended Solids	7	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	7/05/2019	Aluminium (Total)	0.29	0.1	mg/L
Reported	20/05/2019	pH	6.9	6.5-8.5	
Published	20/05/2019	Suspended Solids	6	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	4/06/2019	Aluminium (Total)	0.56	0.1	mg/L
Reported	17/06/2019	pH	7.1	6.5-8.5	
Published	18/06/2019	Suspended Solids	9	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	2/07/2019	Aluminium (Total)	0.27	0.1	mg/L
Reported	10/07/2019	pH	7.4	6.5-8.5	
Published	12/07/2019	Suspended Solids	13	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	6/08/2019	Aluminium (Total)	0.13	0.1	mg/L
Reported	15/08/2019	pH	7.3	6.5-8.5	

Published	21/08/2019	Suspended Solids	3	20	mg/L
		Quantity	Measurement	Limit	Units
Sampled	3/09/2019	Aluminium (Total)	2.34	0.1	mg/L
Reported	11/09/2019	pH	7.6	6.5-8.5	
Published	18/09/2019	Suspended Solids	14	20	mg/L