



Copeton Water Treatment Plant

Licence Period: 20 September 2023 to 19 September 2024		EPL No. 4463: Copeton Water Treatment Plant			
https://apps.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4463&id=4463&option=licence&searchrang=e=licence&range=POEO licence&prp=no&status=Issued		Minnamurra Lane, Inverell NSW 2360			
		Licensee: Inverell Shire Council			
		Monitoring Frequency - Monthly			
Sample date: 04/10/2023	Analysis obtained: 12/10/2023	Data published: 18/10/2023			
	Pollutant	Units	Measurement	Limit	Exceedance (Yes/No)
Monitoring Point 1	Aluminium	mg/L	0.18	0.1	Yes
	pH	-	7.2	6.5 - 8.5	No
	Total Suspended Solids	mg/L	3	20	No
Comments: Changes to settling lagoon infrastructure to reduce discharge concentrations being implemented.					
Sample date: 15/11/2023	Analysis obtained: 23/11/2023	Data published: 24/11/2023			
	Pollutant	Units	Measurement	Limit	Exceedance (Yes/No)
Monitoring Point 1	Aluminium	mg/L	0.36	0.1	Yes
	pH	-	6.9	6.5 - 8.5	No
	Total Suspended Solids	mg/L	8	20	No
Comments: Changes to settling lagoon infrastructure to reduce discharge concentrations being implemented.					
Sample date: 06/12/2023	Analysis obtained: 14/12/2023	Data published: 18/12/2023			
	Pollutant	Units	Measurement	Limit	Exceedance (Yes/No)
Monitoring Point 1	Aluminium	mg/L	0.35	0.1	Yes
	pH	-	7.2	6.5 - 8.5	No
	Total Suspended Solids	mg/L	12	20	No
Comments: Changes to settling lagoon infrastructure to reduce discharge concentrations being implemented.					
Sample date: 10/01/2024	Analysis obtained: 18/01/2024	Data published: 24/01/2024			
	Pollutant	Units	Measurement	Limit	Exceedance (Yes/No)
Monitoring Point 1	Aluminium	mg/L	0.17	0.1	yes
	pH	-	7	6.5 - 8.5	No
	Total Suspended Solids	mg/L	9	20	No
Comments: Changes to settling lagoon infrastructure to reduce discharge concentrations being implemented.					
Sample date: 06/02/2024	Analysis obtained: 07/02/2024	Data published: 15/02/2024			
	Pollutant	Units	Measurement	Limit	Exceedance (Yes/No)
Monitoring Point 1	Aluminium	mg/L	0.09	0.1	No
	pH	-	7	6.5 - 8.5	No
	Total Suspended Solids	mg/L	7	20	No
Comments:					
Sample date: 05/03/2024	Analysis obtained: 14/03/2024	Data published: 19/03/2024			
	Pollutant	Units	Measurement	Limit	Exceedance (Yes/No)
Monitoring Point 1	Aluminium	mg/L	0.25	0.1	Yes
	pH	-	6.8	6.5 - 8.5	No
	Total Suspended Solids	mg/L	10	20	No
Comments: Changes to settling lagoon infrastructure to reduce discharge concentrations being implemented.					
Sample date: 02/04/2024	Analysis obtained: 10/04/2024	Data published: 12/04/2024			
	Pollutant	Units	Measurement	Limit	Exceedance (Yes/No)
Monitoring Point 1	Aluminium	mg/L	0.21	0.1	Yes
	pH	-	6.8	6.5 - 8.5	No
	Total Suspended Solids	mg/L	8	20	No
Comments: Changes to settling lagoon infrastructure to reduce discharge concentrations being implemented.					
Sample date: 08/05/2024	Analysis obtained: 16/05/2024	Data published: 20/05/2024			
	Pollutant	Units	Measurement	Limit	Exceedance (Yes/No)
Monitoring Point 1	Aluminium	mg/L	0.15	0.1	Yes
	pH	-	6.8	6.5 - 8.5	No
	Total Suspended Solids	mg/L	8	20	No
Comments: Changes to settling lagoon infrastructure to reduce discharge concentrations being implemented.					



Copeton Water Treatment Plant

Licence Period: 20 September 2023 to 19 September 2024 EPL No. 4463: Copeton Water Treatment Plant
<https://apps.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=4463&id=4463&option=licence&searchrang=e=licence&range=POEO licence&prp=no&status=Issued> Minnamurra Lane, Inverell NSW 2360
Licensee: Inverell Shire Council
Monitoring Frequency - Monthly

Sample date: 05/06/2024	Analysis obtained: 17/06/2024	Data published: 20/06/2024			
	Pollutant	Units	Measurement	Limit	Exceedance (Yes/No)
Monitoring Point 1	Aluminium	mg/L	0.25	0.1	Yes
	pH	-	6.7	6.5 - 8.5	No
	Total Suspended Solids	mg/L	7	20	no

Comments: Changes to settling lagoon infrastructure to reduce discharge concentrations being implemented.

Sample date:	Analysis obtained:	Data published:			
	Pollutant	Units	Measurement	Limit	Exceedance (Yes/No)
Monitoring Point 1	Aluminium	mg/L		0.1	
	pH	-		6.5 - 8.5	
	Total Suspended Solids	mg/L		20	

Sample date:	Analysis obtained:	Data published:			
	Pollutant	Units	Measurement	Limit	Exceedance (Yes/No)
Monitoring Point 1	Aluminium	mg/L		0.1	
	pH	-		6.5 - 8.5	
	Total Suspended Solids	mg/L		20	

Sample date:	Analysis obtained:	Data published:			
	Pollutant	Units	Measurement	Limit	Exceedance (Yes/No)
Monitoring Point 1	Aluminium	mg/L		0.1	
	pH	-		6.5 - 8.5	
	Total Suspended Solids	mg/L		20	

Comments:

Licence Limit Conditions

L2: Concentration Limits

	Pollutant	Units	100 percentile (calculated - annual)	100 percentile licence limit	Exceedance (Yes/No)
Monitoring Point 1	Aluminium	mg/L		0.1	
	pH	-		6.5 - 8.5	
	Total Suspended Solids	mg/L		20	

L3: Volume and Mass Limits

	Pollutant	Units	Limit	Days/year over limit
Monitoring point 1	Effluent Volume	kL/day	300	

Comments: